

## TWIN & EARTH (6242Y)



### BS TİPİ YASSI TESİSAT KABLOLARI

#### TİP

6242Y

#### STANDART

BS 6004

#### YAPISI

- 1) İletken: BS EN 60228 Sınıf 1-2
- 2) İzole: PVC TİP T11
- 3) Kılıf: PVC TİP 6 BS 7655-4-2

#### KULLANIM

Kuru ve rutubetli yerlerde, sabit aydınlatma tesisatlarında boru içerisinde. Toprak altına döşenmez sabit olarak sıva üzeri ve sıva altında kullanılır.

#### TEKNİK BİLGİLER

Maksimum Çalışma Sıcaklığı: +70°C  
Anma Gerilimi: 300/500V

### TWIN & EARTH CABLES

#### TYPE

6242Y

#### STANDARDS

BS 6004

#### CONSTRUCTION

- 1) Conductor: BS EN 60228 Class 1-2
- 2) Insulation: PVC TYPE T11
- 3) Sheath: PVC TYPE 6 BS 7655-4-2

#### APPLICATIONS

In dry and damp rooms locations and store rooms where subject to fire and explosions hazards, but not for underground laying. For permanent installation clear from or in and under plaster

#### TECHNICAL DATA

Max.Operating Temperature: +70°C  
Rated Voltage: 300/500V

NOMİNAL KESİT (mm <sup>2</sup> )	İZOLASYON ET KALINLIĞI (mm <sup>2</sup> )	DIŞ KILIF ET KALINLIĞI (mm)	ORTALAMA DIŞ ÇAP (mm)	SEVK UZUNLUĞU (m)	YAKLAŞIK AĞIRLIK (kg)
RATED CROSS SECTION	INSULATION THICKNESS	APPROX. OVERALL DIAMETER	APPROX. OVERALL DIAMETER	DELIVERY LENGTH	APPROX. WEIGHT
2x1+1	0.60	0.90	4.40x7.90	100	75
2x1.5+1	0.70	0.90	4.80x8.80	100	94
2x2.5+1.5	0.80	1.00	5.60x10.40	100	136
2x4+1.5	0.80	1.00	6.30x11.80	100	182
2x6+2.5	0.80	1.10	7.10x13.60	1000	251
2x10+4	1.00	1.20	8.50x16.90	1000	395
2x16+6	1.00	1.30	9.80x19.90	1000	576

## TWIN & EARTH (6242Y)



NOMİNAL KESİT (mm <sup>2</sup> )	İZOLASYON ET KALINLIĞI (mm)	DIŞ KILIF ET KALINLIĞI (mm)	ORTALAMA DIŞ ÇAP (mm)	SEVK UZUNLUĞU (m)	YAKLAŞIK AĞIRLIK (kg)
RATED CROSS SECTION	INSULATION THICKNESS (mm)	SHEATH THICKNESS (mm)	APPROX. OVERALL DIAMETER	DELIVERY LENGTH	APPROX. WEIGHT
3x1+1	0.60	0.90	4.35x10.30	100	99
3x1.5+1	0.70	0.90	4.80x11.70	100	126
3x2.5+1	0.80	1.00	5.60x13.70	100	179
3x4+1.5	0.80	1.10	6.50x16.20	100	258
3x6+2.5	0.80	1.10	7.10x18.40	1000	346
3x10+4	1.00	1.20	8.50x22.90	1000	542
3x16+6	1.00	1.30	9.80x27.00	1000	793